



Kiambu Water and Sew. Co. Ltd

P. O Box 409 – 00900 Kiambu
Telephone: 0202133977 / 0716452238

Website: www.kiambuwater.com
Email: info@kiambuwater.com
Kiwasco.water@gmail.com

ADDENDUM NO.1

Date: 17th February 2026

Reference is made to the tenders that were advertised through the PPIP portal and on the Company's website on 10th February 2026.

1. KIWASCO/005/2025-2026 Tender for Supply & Delivery of DWC Waste Water Pipes.

We wish to bring the following amendments to the bidders' attention.

	Request for Clarification	Clarification
1.	Please confirm if you need double socketed pipes as requested in the price schedule or single socketed pipes ?	The company needs Orange Lined, DWC-HDPE waste pipe, Single Socket SN 8 for the assorted sizes (150mm,200mm, 250mm & 300mm) as shown below;

Price Schedule Form

TENDER FOR SUPPLY AND DELIVERY OF DWC WASTE WATER PIPES				
ITEM	DESCRIPTION	UNIT	Estimated Quantity	UNIT RATE IN KENYA SHILLINGS INCLUSIVE OF ALL APPLICABLE TAXES
1.	Orange Lined, DWC-HDPE waste pipe, Single Socket SN 8 – 150mm- with fitting rubber (6 metres)	No.	500	
2.	Orange Lined, DWC-HDPE waste pipe, Single Socket SN 8 – 200mm- with fitting rubber (6 metres)	No.	200	
3.	Orange Lined, DWC-HDPE waste pipe, Single Socket SN 8 – 250mm- with fitting rubber (6 metres)	No.	200	
4.	Orange Lined, DWC-HDPE waste pipe Single Socket SN 8 – 300mm- with fitting rubber (6 metres)	No.	200	

Schedule of Requirements

TENDER FOR SUPPLY AND DELIVERY OF DWC WASTEWATER PIPES			
ITEM	DESCRIPTION	UNIT	Estimated Quantity
1	Orange Lined, DWC-HDPE waste pipe, Single Socket SN 8 – 150mm- with fitting rubber (6 metres)	No.	500
2	Orange Lined, DWC-HDPE waste pipe, Single Socket SN 8 – 200mm- with fitting rubber (6 metres)	No.	200
3	Orange Lined, DWC-HDPE waste pipe, Single Socket SN 8 – 250mm- with fitting rubber (6 metres)	No.	200
4	Orange Lined, DWC-HDPE waste pipe Single Socket SN 8 – 300mm- with fitting rubber (6 metres)	No.	200

All bidders are requested to visit www.kiambuwater.com and the PPIP portal to download the addendum. Bidders are also advised to attach a copy of the addendum notice to the bid document.

The bid closing and opening dates and times remain the same.

Procurement Manager
For Managing Director